



8154 Industrial Park Lane Atchison, KS 66023



Schedule 10

High Strength Steel Fire Sprinkler Pipe

Rev. 0-2024

Schedule 10 steel sprinkler pipe is available in the listed nominal diameters for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or by Listed rubber gasketed fittings as indicated in Underwriters Laboratories Listings under the category for Fittings, Rubber Gasketed (VIZM), when installed in accordance with the fitting manufacturers specifications. It is Factory Mutual approved for roll-grooved, plain-ended and welded lengths for wet systems.

Schedule 10 pipe products are coated with a durable, paintable, environmentally approved acrylic or water-based coating.

Specification: ASTM A795, Grade A, Type E

NPS (inches)	NOMINAL ID (inches)	WALL THICKNESS (inches)	WEIGHT (lb/ft)	WEIGHT H2O FILLED (lb/ft)	NUMBER LENGTHS PER BUNDLE	LENGTH ¹ (ft)	RATED PRESSURE (psi)		CORROSION RESISTANCE RATIO (CRR)	
							UL	FM	SCH. 10	SCH. 40
4	4.260	.120	5.61	11.79	19	21	300	300	1.90	1.0
6	6.357	.134	9.29	23.04	10	21	300	300	1.21	1.0
8	8.249	.188	16.94	40.10	7	21	300	300	1.81	1.0

Notes: 1. - Other lengths are available upon request.

